

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1501:120 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** \*Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410  
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

**DESIGN:** Models EG1-V15, -V30, -V60, -V75 or -V110; Models EG1F-V15, -V30, -V60, V75, -V110; Models EG1R-V15, -V30, -V60, -V75 or -V110; Models EG1RF-V15, -V30, -V60, -V75, -V110 strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 24-30 VDC  
Candela: 15cd, 30cd, 60cd, 75cd, 110cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela rating and UL label.

**APPROVAL:** Listed as strobe lights for use with separately listed compatible fire alarm control units.  
For indoor use and wall mount only.

**XLF:** 7125-1388:232

\*Rev. 06-17-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager